



Facility Tank Information

Facility: **Road Runner Deli Mart**Facility ID No: **4260085**Street: **705 W. 1st St.**Facility Description: **Gas Station**City ST Zip: **Wapato, WA 98951**Operator: **Gary Sybouts**County: **Yakima** Phone: **(509) 877-6202**Tribe: **Yakama**Latitude: **+46° 26' 51.30"** Dec: **46.448 °**LUST Status: **Complete**Longitude: **120° 25' 40.50"** Dec: **-120.428 °**Last Inspection Date: **7/12/2018**Owner: **Yakama Oil Company, Inc.**C&E Status: **Passed**Address: **P.O. Box 1346**SOC Status: **In SOC****Yakima WA 98907**SOC UST Status: **Operating**

Tank Status

Tank ID: **0001**Alt Tank ID: **1**Compartment: ☐ Manifolder: ☐Tank Status: **Permanently Out of Use**Installation Date (Mo/Yr): **3/1/1981**Est. Total Capacity (gallons): **12000**Federally Regulated Tank: ☒

Release Detection

Tank / Pipe

Manual Tank Gauging:	<input type="checkbox"/>	
Tank Tightness Testing:	<input type="checkbox"/>	
Inventory Control:	<input checked="" type="checkbox"/>	
Vapor Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Automatic Tank Gauging:	<input type="checkbox"/>	<input type="checkbox"/>
Interstitial Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
SIR:	<input type="checkbox"/>	<input type="checkbox"/>
Auto Line Leak Detector:	<input type="checkbox"/>	<input type="checkbox"/>
Line Tightness Testing:	<input type="checkbox"/>	<input type="checkbox"/>
Sump Sensor:	<input type="checkbox"/>	<input type="checkbox"/>
Other Method:	<input type="checkbox"/>	<input type="checkbox"/>
Deferred:	<input type="checkbox"/>	<input type="checkbox"/>
Not Listed:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
None:	<input type="checkbox"/>	<input type="checkbox"/>

Tank Information

Tank 1

Clerk: **wmoon**Modified: **4/9/1999 2:08:43 PM**

Tank Construction Material

Tank Material: **Asphalt Coated or Bare Steel**Secondary Material: **None**

Tank Manufacturer:

Tank Repaired: ☐ Used for Emergency Power Generation: ☐

Piping Construction Material

Piping Material: **Galvanized Steel**Secondary Material: **None**

Piping Manufacturer:

Type of Pipe: **Pressurized**Piping Repaired: ☐ Metal in Contact with Ground: ☐

Corrosion Protection

☒ Yes ☐ No ☐ NAFRP/ Flex Pipe: ☐Impressed Current: ☐Sacrificial Anodes: ☐Interior Lining: ☐

Latest Upgrade Install Date:

Spill / Overfill Protection

Spill Protected: ☒Exempt: ☐Overfill Protected: ☒

(Tank filled by transfers no more than 25 gallons at one time.)

(Check all that apply.) Ball Float: ☐Float Restrictor: ☐Outside Alarm: ☐

Substance Currently or Last Stored in Greatest Quantity by Volume

Substance: **Petroleum : Gasoline**

CERCLA No.:

Tank Closure or Change-In-Service

Closure Status: **Tank removed from ground**Closure Observations: **Evidence of Leak Detected**Inert Fill: **None**Site Assessment Completed: ☒Date Last Used: **03/07/1996**Closed Date: **03/22/1996**LUST Trust Fund Tank Removal: ☐

NFA Date:



Facility Tank Information

Facility: **Road Runner Deli Mart**Facility ID No: **4260085**Street: **705 W. 1st St.**Facility Description: **Gas Station**City ST Zip: **Wapato, WA 98951**Operator: **Gary Sybouts**County: **Yakima** Phone: **(509) 877-6202**Tribe: **Yakama**Latitude: **+46° 26' 51.30"** Dec: **46.448 °**LUST Status: **Complete**Longitude: **120° 25' 40.50"** Dec: **-120.428 °**Last Inspection Date: **7/12/2018**Owner: **Yakama Oil Company, Inc.**C&E Status: **Passed**Address: **P.O. Box 1346**SOC Status: **In SOC****Yakima WA 98907**SOC UST Status: **Operating**

Tank Status

Tank ID: **0002**Alt Tank ID: **2**Compartment: ☐ Manifolder: ☐Tank Status: **Permanently Out of Use**Installation Date (Mo/Yr): **3/1/1981**Est. Total Capacity (gallons): **12000**Federally Regulated Tank: ☒

Release Detection

Tank / Pipe

Manual Tank Gauging:	<input type="checkbox"/>	
Tank Tightness Testing:	<input type="checkbox"/>	
Inventory Control:	<input checked="" type="checkbox"/>	
Vapor Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Automatic Tank Gauging:	<input type="checkbox"/>	<input type="checkbox"/>
Interstitial Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
SIR:	<input type="checkbox"/>	<input type="checkbox"/>
Auto Line Leak Detector:	<input type="checkbox"/>	<input type="checkbox"/>
Line Tightness Testing:	<input type="checkbox"/>	<input type="checkbox"/>
Sump Sensor:	<input type="checkbox"/>	<input type="checkbox"/>
Other Method:	<input type="checkbox"/>	<input type="checkbox"/>
Deferred:	<input type="checkbox"/>	<input type="checkbox"/>
Not Listed:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
None:	<input type="checkbox"/>	<input type="checkbox"/>

Tank Information

Tank 2

Clerk: **cboulind**Modified: **10/27/2003 10:37:56 AM**

Tank Construction Material

Tank Material: **Asphalt Coated or Bare Steel**Secondary Material: **None**

Tank Manufacturer:

Tank Repaired: ☐ Used for Emergency Power Generation: ☐

Piping Construction Material

Piping Material: **Galvanized Steel**Secondary Material: **None**

Piping Manufacturer:

Type of Pipe: **Pressurized**Piping Repaired: ☐ Metal in Contact with Ground: ☐

Corrosion Protection

☒ Yes ☐ No ☐ NAFRP/ Flex Pipe: ☐Impressed Current: ☐Sacrificial Anodes: ☐Interior Lining: ☐

Latest Upgrade Install Date:

Substance Currently or Last Stored in Greatest Quantity by Volume

Substance: **Petroleum : Gasoline**

CERCLA No.:

Tank Closure or Change-In-Service

Closure Status: **Tank removed from ground**

Closure Observations:

Inert Fill: **None**Site Assessment Completed: ☒Date Last Used: **03/07/1996**Closed Date: **03/22/1996**LUST Trust Fund Tank Removal: ☐

NFA Date:

Spill / Overfill Protection

Spill Protected: ☒Exempt: ☐Overfill Protected: ☒

(Tank filled by transfers no more than 25 gallons at one time.)

(Check all that apply.) Ball Float: ☐Float Restrictor: ☐Outside Alarm: ☐



Facility Tank Information

Facility: **Road Runner Deli Mart**Facility ID No: **4260085**Street: **705 W. 1st St.**Facility Description: **Gas Station**City ST Zip: **Wapato, WA 98951**Operator: **Gary Sybouts**County: **Yakima** Phone: **(509) 877-6202**Tribe: **Yakama**Latitude: **+46° 26' 51.30"** Dec: **46.448 °**LUST Status: **Complete**Longitude: **120° 25' 40.50"** Dec: **-120.428 °**Last Inspection Date: **7/12/2018**Owner: **Yakama Oil Company, Inc.**C&E Status: **Passed**Address: **P.O. Box 1346**SOC Status: **In SOC****Yakima WA 98907**SOC UST Status: **Operating**

Tank Status

Tank ID: **0003**Alt Tank ID: **3**Compartment: ☐ Manifolder: ☐Tank Status: **Permanently Out of Use**Installation Date (Mo/Yr): **3/1/1981**Est. Total Capacity (gallons): **12000**Federally Regulated Tank: ☒

Release Detection

Tank / Pipe

Manual Tank Gauging:	<input type="checkbox"/>	
Tank Tightness Testing:	<input type="checkbox"/>	
Inventory Control:	<input checked="" type="checkbox"/>	
Vapor Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Automatic Tank Gauging:	<input type="checkbox"/>	<input type="checkbox"/>
Interstitial Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
SIR:	<input type="checkbox"/>	<input type="checkbox"/>
Auto Line Leak Detector:	<input type="checkbox"/>	<input type="checkbox"/>
Line Tightness Testing:	<input type="checkbox"/>	<input type="checkbox"/>
Sump Sensor:	<input type="checkbox"/>	<input type="checkbox"/>
Other Method:	<input type="checkbox"/>	<input type="checkbox"/>
Deferred:	<input type="checkbox"/>	<input type="checkbox"/>
Not Listed:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
None:	<input type="checkbox"/>	<input type="checkbox"/>

Tank Information

Tank 3

Clerk: **cboulind**Modified: **10/27/2003 10:37:55 AM**

Tank Construction Material

Tank Material: **Asphalt Coated or Bare Steel**Secondary Material: **None**

Tank Manufacturer:

Tank Repaired: ☐ Used for Emergency Power Generation: ☐

Piping Construction Material

Piping Material: **Galvanized Steel**Secondary Material: **None**

Piping Manufacturer:

Type of Pipe: **Pressurized**Piping Repaired: ☐ Metal in Contact with Ground: ☐

Corrosion Protection

☒ Yes ☐ No ☐ NAFRP/ Flex Pipe: ☐Impressed Current: ☐Sacrificial Anodes: ☐Interior Lining: ☐

Latest Upgrade Install Date:

Substance Currently or Last Stored in Greatest Quantity by Volume

Substance: **Petroleum : Gasoline**

CERCLA No.:

Tank Closure or Change-In-Service

Closure Status: **Tank removed from ground**

Closure Observations:

Inert Fill: **None**Site Assessment Completed: ☒Date Last Used: **03/07/1996**Closed Date: **03/22/1996**LUST Trust Fund Tank Removal: ☐

NFA Date:

Spill / Overfill Protection

Spill Protected: ☒Exempt: ☐Overfill Protected: ☒

(Tank filled by transfers no more than 25 gallons at one time.)

(Check all that apply.) Ball Float: ☐Float Restrictor: ☐Outside Alarm: ☐



Facility Tank Information

Facility: **Road Runner Deli Mart**Facility ID No: **4260085**Street: **705 W. 1st St.**Facility Description: **Gas Station**City ST Zip: **Wapato, WA 98951**Operator: **Gary Sybouts**County: **Yakima** Phone: **(509) 877-6202**Tribe: **Yakama**Latitude: **+46° 26' 51.30"** Dec: **46.448 °**LUST Status: **Complete**Longitude: **120° 25' 40.50"** Dec: **-120.428 °**Last Inspection Date: **7/12/2018**Owner: **Yakama Oil Company, Inc.**C&E Status: **Passed**Address: **P.O. Box 1346**SOC Status: **In SOC****Yakima WA 98907**SOC UST Status: **Operating**

Tank Status

Tank ID: **0004**Alt Tank ID: **4**Compartment: ☐ Manifolder: ☐Tank Status: **Currently in Use**Installation Date (Mo/Yr): **4/25/1996**Est. Total Capacity (gallons): **12000**Federally Regulated Tank: ☒

Release Detection

Tank / Pipe

Manual Tank Gauging:	<input type="checkbox"/>	
Tank Tightness Testing:	<input type="checkbox"/>	
Inventory Control:	<input checked="" type="checkbox"/>	
Vapor Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Automatic Tank Gauging:	<input checked="" type="checkbox"/>	
Interstitial Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
SIR:	<input type="checkbox"/>	<input type="checkbox"/>
Auto Line Leak Detector:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Line Tightness Testing:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sump Sensor:	<input type="checkbox"/>	<input type="checkbox"/>
Other Method:	<input type="checkbox"/>	<input type="checkbox"/>
Deferred:	<input type="checkbox"/>	<input type="checkbox"/>
Not Listed:	<input type="checkbox"/>	<input type="checkbox"/>
None:	<input type="checkbox"/>	<input type="checkbox"/>

Tank Information

Tank 4

Clerk: **JGreeves**Modified: **9/14/2006 3:45:53 PM**

Tank Construction Material

Tank Material: **Composite (Steel w/ FRP)**Secondary Material: **Double-Walled**

Tank Manufacturer:

Tank Repaired: ☐ Used for Emergency Power Generation: ☐

Piping Construction Material

Piping Material: **Flexible Plastic**Secondary Material: **Double-Walled**Piping Manufacturer: **Environ**Type of Pipe: **Pressurized**Piping Repaired: ☐ Metal in Contact with Ground: ☐

Corrosion Protection

☒ Yes ☐ No ☐ NAFRP/ Flex Pipe: ☐Impressed Current: ☐Sacrificial Anodes: ☐Interior Lining: ☐

Latest Upgrade Install Date:

Spill / Overfill Protection

Spill Protected: ☒Exempt: ☐Overfill Protected: ☒

(Tank filled by transfers no more than 25 gallons at one time.)

(Check all that apply.)

Ball Float: ☒Float Restrictor: ☐Outside Alarm: ☐

Substance Currently or Last Stored in Greatest Quantity by Volume

Substance: **Petroleum : Gasoline**

CERCLA No.:

Tank Closure or Change-In-Service

Closure Status:

Closure Observations:

Inert Fill:

Site Assessment Completed: ☐

Date Last Used:

Closed Date:

LUST Trust Fund Tank Removal: ☐

NFA Date:



Facility Tank Information

Facility:	Road Runner Deli Mart	Facility ID No:	4260085
Street:	705 W. 1st St.	Facility Description:	Gas Station
City ST Zip:	Wapato, WA 98951	Operator:	Gary Sybouts
County:	Yakima	Tribe:	Yakama
Phone:	(509) 877-6202		
Latitude:	+46° 26' 51.30"	Dec:	46.448 °
Longitude:	120° 25' 40.50"	Dec:	-120.428 °
Owner:	Yakama Oil Company, Inc.	LUST Status:	Complete
Address:	P.O. Box 1346	Last Inspection Date:	7/12/2018
	Yakima WA 98907	C&E Status:	Passed
		SOC Status:	In SOC
		SOC UST Status:	Operating

Tank Comments

Source	Date	Comments
Tank	10/27/03	Regular unleaded grade. CMB 10/27/03
Tank	10/27/03	Image II ATG can only do IC; no leak tests. Must replace primary method of IC & TTT by 4/2006. CMB 10/27/03 Environ piping. CMB 10/27/03
JGreeves	09/14/06	Installed a new Veeder-Root TLS350 w/CSLD in July 2006



Facility Tank Information

Facility: **Road Runner Deli Mart**Facility ID No: **4260085**Street: **705 W. 1st St.**Facility Description: **Gas Station**City ST Zip: **Wapato, WA 98951**Operator: **Gary Sybouts**County: **Yakima** Phone: **(509) 877-6202**Tribe: **Yakama**Latitude: **+46° 26' 51.30"** Dec: **46.448 °**LUST Status: **Complete**Longitude: **120° 25' 40.50"** Dec: **-120.428 °**Last Inspection Date: **7/12/2018**Owner: **Yakama Oil Company, Inc.**C&E Status: **Passed**Address: **P.O. Box 1346**SOC Status: **In SOC****Yakima WA 98907**SOC UST Status: **Operating**

Tank Status

Tank ID: **0005**Alt Tank ID: **5a**Compartment: ☒ Manifolder: ☐Tank Status: **Currently in Use**Installation Date (Mo/Yr): **4/25/1996**Est. Total Capacity (gallons): **6000**Federally Regulated Tank: ☒

Tank Construction Material

Tank Material: **Composite (Steel w/ FRP)**Secondary Material: **Double-Walled**

Tank Manufacturer:

Tank Repaired: ☐ Used for Emergency Power Generation: ☐

Piping Construction Material

Piping Material: **Flexible Plastic**Secondary Material: **Double-Walled**Piping Manufacturer: **Environ**Type of Pipe: **Pressurized**Piping Repaired: ☐ Metal in Contact with Ground: ☐

Corrosion Protection

☒ Yes ☐ No ☐ NAFRP/ Flex Pipe: ☐Impressed Current: ☐Sacrificial Anodes: ☐Interior Lining: ☐

Latest Upgrade Install Date:

Spill / Overfill Protection

Spill Protected: ☒ Exempt: ☐Overfill Protected: ☒
(Tank filled by transfers no more than 25 gallons at one time.)(Check all that apply.) Ball Float: ☒Float Restrictor: ☐Outside Alarm: ☐

Release Detection

Tank / Pipe

Manual Tank Gauging:	<input type="checkbox"/>	<input type="checkbox"/>
Tank Tightness Testing:	<input type="checkbox"/>	<input type="checkbox"/>
Inventory Control:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vapor Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Automatic Tank Gauging:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Interstitial Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
SIR:	<input type="checkbox"/>	<input type="checkbox"/>
Auto Line Leak Detector:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Line Tightness Testing:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sump Sensor:	<input type="checkbox"/>	<input type="checkbox"/>
Other Method:	<input type="checkbox"/>	<input type="checkbox"/>
Deferred:	<input type="checkbox"/>	<input type="checkbox"/>
Not Listed:	<input type="checkbox"/>	<input type="checkbox"/>
None:	<input type="checkbox"/>	<input type="checkbox"/>

Tank Information

Tank 5

Clerk: **JGreeves**Modified: **9/14/2006 3:46:09 PM**ATG Mfg: **Veeder-Root**ATG Model: **TLS350 w/CSLD**

IM Mfg:

IM Model:

SIR Vendor:

SIR Ver:

Type of ALLD: **MLLD**ALLD Mfg: **FE Petro**

Substance Currently or Last Stored in Greatest Quantity by Volume

Substance: **Petroleum : Gasoline**

CERCLA No.:

Tank Closure or Change-In-Service

Closure Status:

Closure Observations:

Inert Fill:

Site Assessment Completed: ☐

Date Last Used:

Closed Date:

LUST Trust Fund Tank Removal: ☐

NFA Date:



Facility Tank Information

Facility:	Road Runner Deli Mart	Facility ID No:	4260085
Street:	705 W. 1st St.	Facility Description:	Gas Station
City ST Zip:	Wapato, WA 98951	Operator:	Gary Sybouts
County:	Yakima	Phone:	(509) 877-6202
Latitude:	+46° 26' 51.30"	Dec:	46.448 °
Longitude:	120° 25' 40.50"	Dec:	-120.428 °
Owner:	Yakama Oil Company, Inc.	Tribe:	Yakama
Address:	P.O. Box 1346	LUST Status:	Complete
	Yakima WA 98907	Last Inspection Date:	7/12/2018
		C&E Status:	Passed
		SOC Status:	In SOC
		SOC UST Status:	Operating

Tank Comments

Source	Date	Comments
Tank	10/27/03	Super unleaded grade. CMB 10/27/03 \\\ Environ piping. CMB 10/27/03 \\\ Two compartment UST evenly split at 6,000 gallon capacity each, totaling 12,000 gallons. CMB 10/27/03
Tank	10/27/03	Image II ATG can only do IC; no leak tests. Must replace primary method of IC & TTT by 4/2006. CMB 10/27/03
JGreeves	09/14/06	Installed a new Veeder-Root TLS350 w/CSLD in July 2006



Facility Tank Information

Facility: **Road Runner Deli Mart**Facility ID No: **4260085**Street: **705 W. 1st St.**Facility Description: **Gas Station**City ST Zip: **Wapato, WA 98951**Operator: **Gary Sybouts**County: **Yakima** Phone: **(509) 877-6202**Tribe: **Yakama**Latitude: **+46° 26' 51.30"** Dec: **46.448 °**LUST Status: **Complete**Longitude: **120° 25' 40.50"** Dec: **-120.428 °**Last Inspection Date: **7/12/2018**Owner: **Yakama Oil Company, Inc.**C&E Status: **Passed**Address: **P.O. Box 1346**SOC Status: **In SOC****Yakima WA 98907**SOC UST Status: **Operating**

Tank Status

Tank ID: **0006**Alt Tank ID: **5b**Compartment: ☒ Manifolder: ☐Tank Status: **Currently In Use**Installation Date (Mo/Yr): **4/25/1996**Est. Total Capacity (gallons): **6000**Federally Regulated Tank: ☒

Release Detection

Tank / Pipe

Manual Tank Gauging:	<input type="checkbox"/>	<input type="checkbox"/>
Tank Tightness Testing:	<input type="checkbox"/>	<input type="checkbox"/>
Inventory Control:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Vapor Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Groundwater Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
Automatic Tank Gauging:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Interstitial Monitoring:	<input type="checkbox"/>	<input type="checkbox"/>
SIR:	<input type="checkbox"/>	<input type="checkbox"/>
Auto Line Leak Detector:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Line Tightness Testing:	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sump Sensor:	<input type="checkbox"/>	<input type="checkbox"/>
Other Method:	<input type="checkbox"/>	<input type="checkbox"/>
Deferred:	<input type="checkbox"/>	<input type="checkbox"/>
Not Listed:	<input type="checkbox"/>	<input type="checkbox"/>
None:	<input type="checkbox"/>	<input type="checkbox"/>

Tank Information

Tank 6

Clerk: **JGreeves**Modified: **9/14/2006 3:47:59 PM**

Tank Construction Material

Tank Material: **Composite (Steel w/ FRP)**Secondary Material: **Double-Walled**Tank Manufacturer: Tank Repaired: ☐ Used for Emergency Power Generation: ☐

Piping Construction Material

Piping Material: **Flexible Plastic**Secondary Material: **Double-Walled**Piping Manufacturer: **Environ**Type of Pipe: **Pressurized**Piping Repaired: ☐ Metal in Contact with Ground: ☐

Corrosion Protection

☒ Yes ☐ No ☐ NAFRP/ Flex Pipe: ☐Impressed Current: ☐Sacrificial Anodes: ☐Interior Lining: ☐Latest Upgrade Install Date:

Spill / Overfill Protection

Spill Protected: ☒ Exempt: ☐Overfill Protected: ☒
(Check all that apply.) Ball Float: ☒
Float Restrictor: ☐
Outside Alarm: ☐
(Tank filled by transfers no more than 25 gallons at one time.)

Substance Currently or Last Stored in Greatest Quantity by Volume

Substance: **Petroleum : Gasoline**CERCLA No.:

Tank Closure or Change-In-Service

Closure Status: Closure Observations: Inert Fill: Site Assessment Completed: ☐ Date Last Used: LUST Trust Fund Tank Removal: ☐ Closed Date: NFA Date:



Facility Tank Information

Facility:	Road Runner Deli Mart	Facility ID No:	4260085
Street:	705 W. 1st St.	Facility Description:	Gas Station
City ST Zip:	Wapato, WA 98951	Operator:	Gary Sybouts
County:	Yakima	Tribe:	Yakama
Phone:	(509) 877-6202		
Latitude:	+46° 26' 51.30"	Dec:	46.448 °
Longitude:	120° 25' 40.50"	Dec:	-120.428 °
Owner:	Yakama Oil Company, Inc.		
Address:	P.O. Box 1346		
	Yakima WA 98907		
		LUST Status:	Complete
		Last Inspection Date:	7/12/2018
		C&E Status:	Passed
		SOC Status:	In SOC
		SOC UST Status:	Operating

Tank Comments

Source	Date	Comments
Tank	10/27/03	Mid-grade unleaded gasoline. CMB 10/27/03 \ \ Two compartment UST evenly split at 6,000 gallon capacity each, totaling 12,000 gallons. CMB 10/27/03 \ \ \ Environ piping. CMB 10/27/03
Tank	10/27/03	Image II ATG can only do IC; no leak tests. Must replace primary method of IC & TTT by 4/2006. CMB 10/27/03
JGreeves	09/14/06	Installed a new Veeder-Root TLS350 w/CSLD in July 2006